SIEMENS

Product data sheet

3RT1015-1BF41



CONTACTOR, AC-3 3 KW/400 V, 1 NO, DC 110 V, 3-POLE, SIZE S00, SCREW CONNECTION


General technical data: product brand name SIRIUS Size of the contactor S00 Protection close IB / on the front ID20	
Size of the contactor S00	
Protection class IP / on the front IP20	
Degree of pollution 3	
Installation altitude / at a height over sea level / maximum m 2,000	
Ambient temperature / during operating°C-25 +60	
Mechanical operating cycles as operating time	
• of the contactor / typical 30,000,000	
• of the contactor with added auxiliary switch block / typical 10,000,000	
of the contactor with added electronics-compatible auxiliary 5,000,000 switch block / typical	
Main circuit:	
Number of NC contacts / for main contacts 0	
Number of NO contacts / for main contacts 3	
Operating current	
• at AC-1 / at 400 V	
• at 40 °C ambient temperature / rated value A 18	
• at AC-3 / at 400 V / rated value A 7	
• at AC-4 / at 400 V / rated value A 6.5	


• with 1 current path / at DC-1		
• at 24 V / rated value	А	15
• at 110 V / rated value	А	1.5
• with 2 current paths in series / at DC-1		
• at 24 V / rated value	А	15
• at 110 V / rated value	А	8.4
• with 3 current paths in series / at DC-1		
• at 24 V / rated value	А	15
• at 110 V / rated value	А	15
• with 1 current path / at DC-3 / at DC-5		
• at 24 V / rated value	А	15
• at 110 V / rated value	А	0.1
• with 2 current paths in series / at DC-3 / at DC-5		
• at 24 V / rated value	А	15
• at 110 V / rated value	А	0.25
• with 3 current paths in series / at DC-3 / at DC-5		
• at 24 V / rated value	А	15
• at 110 V / rated value	А	15
Service power		
• at AC-2 / at 400 V / rated value	kW	3
• at AC-3 / at 400 V / rated value	kW	3
• at AC-4 / at 400 V / rated value	W	3,000
Control circuit:		
Voltage type / of control feed voltage		DC
Operating range factor control supply voltage rated value / of the magnet coil		
• for DC		0.85 1.1
Pull-in power / of the solenoid / for DC	W	3.3
Holding power / of the solenoid / for DC	W	3.3
Auxiliary circuit:		
Contact reliability / of the auxiliary contacts	-	1 faulty switching per 100 million (17 V, 1 mA)
		1 faulty switching per 100 million (17 V, 1 mA) 0
Contact reliability / of the auxiliary contacts Number of NC contacts / for auxiliary contacts / instantaneous		
Contact reliability / of the auxiliary contacts Number of NC contacts / for auxiliary contacts / instantaneous switching Number of NO contacts / for auxiliary contacts / instantaneous		0
Contact reliability / of the auxiliary contacts Number of NC contacts / for auxiliary contacts / instantaneous switching Number of NO contacts / for auxiliary contacts / instantaneous switching		0
Contact reliability / of the auxiliary contacts Number of NC contacts / for auxiliary contacts / instantaneous switching Number of NO contacts / for auxiliary contacts / instantaneous switching Short-circuit:		0

 with type of assignment 1 / required 		fuse gL/gG: 35 A
• at type of coordination 2 / required	ordination 2 / required	
Installation/mounting/dimensions:		
Mounting type		screw and snap-on mounting onto 35 mm standard mounting rail according to DIN EN 50022
series installation		Yes
Width	mm	45
Height	mm	57.5
Depth	mm	72
Distance, to be maintained, to earthed part / sidewards	mm	6
Connection type:		
Connection type:		
Design of the electrical connection		
for main current circuit		screw-type terminals
for auxiliary and control current circuit		screw-type terminals
Type of the connectable conductor cross-section		
• for main contacts		
• solid		2x (0.5 1.5 mm ²), 2x (0.75 2.5 mm ²), max. 2x (0.75 4 mm ²)
finely stranded		, , ,
with conductor end processing		2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²)
for AWG conductors / for main contacts		2x (20 16), 2x (18 14), 1x 12
for auxiliary contacts		
• solid		2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²), max. 2x (0.75 4 mm²)
finely stranded		
• with conductor end processing		2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²)

Certificates/approvals:

	(SA	EHC	KETI		SN UR
Functional Safety / Safety of Machinery	Declaration of Conformity	Test Certificates			
Type Examination	CE EG-Konf.	Special Test Certificate			
Shipping Approval					
ABS		GL	Lloyd's Register Lrs	PRS	RINA
Shipping Approval	other				
RMRS	<u>Confirmation</u>	<u>other</u>	Environmental Confirmations		
urther informatio	n:				
formation- and Dow tp://www.siemens.co		-			
ndustry Mall (Online http://www.siemens.co		'mall			
ax online generator ttp://www.siemens.co					
		Characteristics, FAQs,. //view/en/3RT1015-1BF4	-		
nage database (prod	duct images, 2D din	nension drawings, 3D m	odels, device circuit d	diagrams,)	





last change:

Apr 30, 2014