



NEOZED FUSE LINK 400V GL, SIZE D01, 16A IN FOLDING BOX

Figure similar

Model		
product brand name		SETRON
Product variations		Pack of 10
Design of the fuse link		NEOZED fuse links
General technical data		
Size of fuse system / acc. to DIN EN 60269-1		D01
Operating class of the fuse link		gG
circuit-breaker / Design		5SE2
Supply voltage		
• with AC / Rated value	V	400
Protection class		
Protection class IP		IP20, with connected conductors
Switching capacity		
Switching capacity current / acc. to IEC 60947-2 / Rated value	kA	50
Dissipation		
Active power loss		
• for rated value of the current / with AC / in hot operating state / per pole	W	1.6
Electricity		
rated current I _n / IEC, DIN/VDE / at 40 Cel	A	15.2
Current / with AC / Rated value	A	16
Appearance		

Color coding of the fuse link		gray
-------------------------------	--	------

Mechanical Design

mounting position		Any, preferably vertical
Net weight	g	5

Environmental conditions

Ambient temperature		
• minimum	°C	-5
• maximum	°C	40

General Product Approval	Declaration of Conformity	Test Certificates
---------------------------------	----------------------------------	--------------------------



ÖVE



GOST



VDE



EG-Konf.

[Special Test Certificate](#)

Test Certificates	other
--------------------------	--------------

[Type Test Certificates/Test Report](#)

[other](#)

[Environmental Confirmations](#)

Further information

Information- and Downloadcenter (Catalogs, Brochures,...)

<http://www.siemens.com/lowvoltage/catalogs>

Industry Mall (Online ordering system)

<https://eb.automation.siemens.com/mall/en/WW/Catalog/Product/5SE2316>

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

<http://support.automation.siemens.com/WW/view/en/5SE2316/all>

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)


http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=5SE2316

CAX-Online-Generator


<http://www.siemens.com/cax>

Tender specifications

<http://ausschreibungstexte.siemens.com/tiplv>



last modified:



05.05.2015